

## Summary Report of Hazardous Waste and Sewage Spill Incidents per Water Code Section 13271

### I. Petroleum Products

| Date Reported* | Date Discovered | Location                               | Discharger               | Problem                                                   | Action                    |
|----------------|-----------------|----------------------------------------|--------------------------|-----------------------------------------------------------|---------------------------|
| 6/4/01         | 2/8/01          | 895 SECOND STREET, SAN BERNARDINO      | ALLEN PROPERTY           | UNDERGROUND STORAGE TANK LEAK: GASOLINE CONTAMINATED SOIL | INVESTIGATION IN PROGRESS |
| 6/4/01         | 10/23/00        | 2445 BALL ROAD, ANAHEIM                | DARRELL FAH              | UNDERGROUND STORAGE TANK LEAK: GASOLINE CONTAMINATED SOIL | INVESTIGATION IN PROGRESS |
| 6/4/01         | 1/15/01         | 12240 SEAL BEACH BOULEVARD, SEAL BEACH | NICK PUIG                | UNDERGROUND STORAGE TANK LEAK: GASOLINE CONTAMINATED SOIL | INVESTIGATION IN PROGRESS |
| 6/4/01         | 4/11/01         | 9690 CENTRAL AVENUE, MONTCLAIR         | ARCO PRODUCTS COMPANY    | UNDERGROUND STORAGE TANK LEAK: GASOLINE CONTAMINATED SOIL | INVESTIGATION IN PROGRESS |
| 5/24/01        | 1/13/98         | 11416 BRYANT STREET, YUCAIPA           | STEVE SHAW               | UNDERGROUND STORAGE TANK LEAK: GASOLINE CONTAMINATED SOIL | INVESTIGATION IN PROGRESS |
| 5/16/01        | 11/22/00        | 2292 LA SIERRA AVENUE, RIVERSIDE       | JOHN ERWIN               | UNDERGROUND STORAGE TANK LEAK: GASOLINE CONTAMINATED SOIL | INVESTIGATION IN PROGRESS |
| 5/16/01        | 11/3/00         | 906 N. WATERMAN AVENUE, SAN BERNARDINO | STEWART AND LINDA ALDER  | UNDERGROUND STORAGE TANK LEAK: GASOLINE CONTAMINATED SOIL | INVESTIGATION IN PROGRESS |
| 4/24/01        | 4/24/01         | 1515 LEWIS, ANAHEIM                    | TOSCO OIL CORPORATION    | UNDERGROUND STORAGE TANK LEAK: DIESEL CONTAMINATED SOIL   | INVESTIGATION IN PROGRESS |
| 4/4/01         | 4/28/99         | 2266 N. SIERRA WAY, SAN BERNARDINO     | ABDUL HAMID              | UNDERGROUND STORAGE TANK LEAK: GASOLINE CONTAMINATED SOIL | INVESTIGATION IN PROGRESS |
| 3/28/01        | 1/22/01         | 4465 E. MISSION BLVD, MONTCLAIR        | TONY BROWN               | UNDERGROUND STORAGE TANK LEAK: GASOLINE CONTAMINATED SOIL | INVESTIGATION IN PROGRESS |
| 3/22/01        | 10/9/00         | 5981 WARNER AVENUE, HUNTINGTON BEACH   | DARRELL FAH              | UNDERGROUND STORAGE TANK LEAK: GASOLINE CONTAMINATED SOIL | INVESTIGATION IN PROGRESS |
| 3/20/01        | 10/29/87        | 2929 HARBOR BOULEVARD, COSTA MESA      | MICHAEL BAUMAN           | UNDERGROUND STORAGE TANK LEAK: GASOLINE CONTAMINATED SOIL | INVESTIGATION IN PROGRESS |
| 3/12/01        | 11/22/00        | 16090 FOOTHILL BLVD, FONTANA           | CHRIS PANAITESCU         | UNDERGROUND STORAGE TANK LEAK: GASOLINE CONTAMINATED SOIL | INVESTIGATION IN PROGRESS |
| 2/23/01        | 2/8/01          | 895 2ND STREET, SAN BERNARDINO         | MICHAEL AND BRENDA ALLEN | UNDERGROUND STORAGE TANK LEAK: GASOLINE CONTAMINATED SOIL | INVESTIGATION IN PROGRESS |
| 11/21/00       | 11/12/00        | 18600 VAN BUREN, RIVERSIDE             | GILBERT MCAULEY          | UNDERGROUND STORAGE TANK LEAK: GASOLINE CONTAMINATED SOIL | INVESTIGATION IN PROGRESS |
| 10/31/00       | 10/31/00        | 2504 E. CHAPMAN AVE., ORANGE           | NICK PUIG                | UNDERGROUND STORAGE TANK LEAK: GASOLINE CONTAMINATED SOIL | INVESTIGATION IN PROGRESS |

\*Report date is the date on the Unauthorized Release Report which is filled out by the local agency or the discharger.

## Summary Report of Hazardous Waste and Sewage Spill Incidents per Water Code Section 13271

### I. Petroleum Products

| Date Reported* | Date Discovered | Location                               | Discharger                     | Problem                                                    | Action                    |
|----------------|-----------------|----------------------------------------|--------------------------------|------------------------------------------------------------|---------------------------|
| 10/25/00       | 10/2/00         | 906 N. WATERMAN AVENUE, SAN BERNARDINO | STEWART & WILMA ALDER          | UNDERGROUND STORAGE TANK LEAK: GASOLINE CONTAMINATED SOIL  | INVESTIGATION IN PROGRESS |
| 10/6/00        | 10/5/00         | 2292 LA SIERRA AVE, RIVERSIDE          | JOHN ERWIN                     | UNDERGROUND STORAGE TANK LEAK: GASOLINE CONTAMINATED SOIL  | INVESTIGATION IN PROGRESS |
| 9/26/00        | 7/28/00         | 9668 REDWOOD AVE, FONTANA              | GRIGOR TERMENJIAN              | UNDERGROUND STORAGE TANK LEAK: DIESEL CONTAMINATED SOIL    | INVESTIGATION IN PROGRESS |
| 8/23/00        | 7/10/00         | 503 PALMYRITA AVE, HIGHGROVE           | LATIMER PARCEL                 | UNDERGROUND STORAGE TANK LEAK: GASOLINE CONTAMINATED SOIL  | INVESTIGATION IN PROGRESS |
| 8/21/00        | 6/30/99         | 1501 HARBOR BLVD, COSTA MESA           | STATE OF CA. DEPT. GENERAL SER | UNDERGROUND STORAGE TANK LEAK: DIESEL CONTAMINATED SOIL    | INVESTIGATION IN PROGRESS |
| 8/16/00        | 8/16/00         | 33986 ORANGE ST, WILDOMAR              | ARCO PRODUCTS CO.              | UNDERGROUND STORAGE TANK LEAK: GASOLINE CONTAMINATED SOIL  | INVESTIGATION IN PROGRESS |
| 8/14/00        | 8/3/00          | 211 MAIN ST, ORANGE                    | SUNBURST LLC                   | UNDERGROUND STORAGE TANK LEAK: GASOLINE CONTAMINATED SOIL  | INVESTIGATION IN PROGRESS |
| 8/14/00        | 7/31/00         | 521 KATELLA, ORANGE                    | NISSON, ART                    | UNDERGROUND STORAGE TANK LEAK: WASTE OIL CONTAMINATED SOIL | INVESTIGATION IN PROGRESS |
| 8/8/00         |                 | 2501-2509 1ST ST, SANTA ANA            | BLANK RP                       | UNDERGROUND STORAGE TANK LEAK: GASOLINE CONTAMINATED SOIL  | INVESTIGATION IN PROGRESS |
| 8/7/00         | 10/20/99        | 13568 MILLIKEN AVE, ONTARIO            | SOUTHERN CALIFORNIA EDISON     | UNDERGROUND STORAGE TANK LEAK: GASOLINE CONTAMINATED SOIL  | INVESTIGATION IN PROGRESS |
| 8/3/00         | 8/3/00          | 11880 MAGNOLIA AVE, RIVERSIDE          | MOBIL OIL CORP                 | UNDERGROUND STORAGE TANK LEAK: GASOLINE CONTAMINATED SOIL  | INVESTIGATION IN PROGRESS |
| 8/3/00         | 8/3/00          | 211 MAIN ST, ORANGE                    | ZADEH MEYER ENGINEERING, INC   | UNDERGROUND STORAGE TANK LEAK: WASTE OIL CONTAMINATED SOI  | INVESTIGATION IN PROGRESS |
| 8/2/00         | 2/28/86         | 100 BEACH BLVD, ANAHEIM                | MOBIL OIL CORPORATION          | UNDERGROUND STORAGE TANK LEAK: GASOLINE CONTAMINATED SOIL  | INVESTIGATION IN PROGRESS |
| 8/1/00         |                 | 219 1ST ST, SANTA ANA                  | HARRIS TAYLOR MANAGEMENT       | UNDERGROUND STORAGE TANK LEAK: GASOLINE CONTAMINATED SOIL  | INVESTIGATION IN PROGRESS |
| 7/31/00        | 7/31/00         | 1973 AVIATION DR, CORONA               | CORONA MUNICIPAL AIRPORT       | UNDERGROUND STORAGE TANK LEAK: JET FUEL CONTAMINATED SOIL  | INVESTIGATION IN PROGRESS |
| 7/28/00        | 10/14/87        | 520 GOETZ, SANTA ANA                   | JAMES KOCH TRUST               | UNDERGROUND STORAGE TANK LEAK: GASOLINE CONTAMINATED SOIL  | INVESTIGATION IN PROGRESS |
| 7/27/00        | 9/2/98          | 11292 WESTERN AVE, STANTON             | CR&R                           | UNDERGROUND STORAGE TANK LEAK: GASOLINE CONTAMINATED SOIL  | INVESTIGATION IN PROGRESS |

\*Report date is the date on the Unauthorized Release Report which is filled out by the local agency or the discharger.

## Summary Report of Hazardous Waste and Sewage Spill Incidents per Water Code Section 13271

### I. Petroleum Products

| Date Reported* | Date Discovered | Location                                 | Discharger                      | Problem                                                      | Action                       |
|----------------|-----------------|------------------------------------------|---------------------------------|--------------------------------------------------------------|------------------------------|
| 6/19/00        |                 | 3150 CHINO HILLS PARKWAY,<br>CHINO HILLS | ABBONA PROPERTY                 | UNDERGROUND STORAGE TANK LEAK: GASOLINE<br>CONTAMINATED SOIL | INVESTIGATION IN<br>PROGRESS |
| 5/16/00        |                 | 1929 AVIATION DR, CORONA                 | CORONA AIR SERVICE              | UNDERGROUND STORAGE TANK LEAK: JET FUEL<br>CONTAMINATED SOIL | INVESTIGATION IN<br>PROGRESS |
| 3/20/00        | 3/20/00         | 213 WEST VALLEY BLVD., RIALTO            | GM. CLEMONS-BROWN               | UNDERGROUND STORAGE TANK LEAK: DIESEL<br>CONTAMINATED SOIL   | INVESTIGATION IN<br>PROGRESS |
| 3/14/00        | 12/9/99         | 22144 ALESSANDRO BLVD,<br>RIVERSIDE      | MILLER, DICK                    | UNDERGROUND STORAGE TANK LEAK: GASOLINE<br>CONTAMINATED SOIL | INVESTIGATION IN<br>PROGRESS |
| 1/20/00        |                 | EASTSIDE RESERVOIR/ EAST<br>DAM, HEMET   | KIEWIT-GRANITE<br>CONSTRUCTION  | UNDERGROUND STORAGE TANK LEAK: DIESEL<br>CONTAMINATED SOIL   | INVESTIGATION IN<br>PROGRESS |
| 1/14/00        |                 | 12345 CENTRAL AVE, CHINO                 | THRIFTY OIL CO                  | UNDERGROUND STORAGE TANK LEAK: GASOLINE<br>CONTAMINATED SOIL | INVESTIGATION IN<br>PROGRESS |
| 1/10/00        | 10/15/99        | 1901 VIA BURTON, FULLERTON               | MORINGSTAR FOODS INC            | UNDERGROUND STORAGE TANK LEAK: GASOLINE<br>CONTAMINATED SOIL | INVESTIGATION IN<br>PROGRESS |
| 11/16/99       |                 | 2314 PACIFIC ST, ORANGE                  | RICK HAMM CONSTRUCTION          | UNDERGROUND STORAGE TANK LEAK: GASOLINE<br>CONTAMINATED SOIL | INVESTIGATION IN<br>PROGRESS |
| 11/1/99        |                 | 7845 SANTIAGO CANYON RD,<br>ORANGE       | DIOCESE OF ORANGE               | UNDERGROUND STORAGE TANK LEAK: GASOLINE<br>CONTAMINATED SOIL | INVESTIGATION IN<br>PROGRESS |
| 10/21/99       |                 | 2200 BATAVIA, ORANGE                     | CONSOLIDATED<br>FREIGHTWAYS     | UNDERGROUND STORAGE TANK LEAK: GASOLINE<br>CONTAMINATED SOIL | INVESTIGATION IN<br>PROGRESS |
| 11/13/98       | 11/13/98        | USMCAS EL TORO-UST 404, EL<br>TORO       | US MCAS EL TORO                 | UNDERGROUND STORAGE TANK LEAK: DIESEL<br>CONTAMINATED SOIL   | INVESTIGATION IN<br>PROGRESS |
| 9/29/98        | 6/10/97         | USMCAS EL TORO-UST 314A,B,D,<br>EL TORO  | US MCAS EL TORO                 | UNDERGROUND STORAGE TANK LEAK: DIESEL<br>CONTAMINATED SOIL   | INVESTIGATION IN<br>PROGRESS |
| 6/24/98        | 3/2/98          | USMCAS EL TORO-BLDG 335, EL<br>TORO      | US MARINE CORPS                 | UNDERGROUND STORAGE TANK LEAK: DIESEL<br>CONTAMINATED SOIL   | INVESTIGATION IN<br>PROGRESS |
| 10/29/86       | 9/26/86         | 503 EDGEWATER AVE, BALBOA                | FRANKLIN INTERVIVOS<br>TRUST II | UNDERGROUND STORAGE TANK LEAK: GASOLINE<br>CONTAMINATED SOIL | INVESTIGATION IN<br>PROGRESS |

Due to the transition from the Leaking Underground Storage Tank FUEL database to the GEIMS/GEOTRACKER database, we are in the process of entering new cases into the GEIMS/GEOTRACKER database. The next quarterly report will include additional UST cases that were reported in the last several quarters, but were not entered into the GEIMS/GEOTRACKER database this quarter.

## SANTA ANA REGIONAL WATER QUALITY CONTROL BOARD

### SEWAGE SPILL INCIDENTS (500 GALLONS AND ABOVE)

| Reported Date | Date of Spill | Notif. No. | Responsible Party | Incident Location                                                                                 | Spill Type | Volume Spilled | Description of Incident                                                                                                                                                                                                                                                                                                                                                         |
|---------------|---------------|------------|-------------------|---------------------------------------------------------------------------------------------------|------------|----------------|---------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| 4/30/01       | 4/30/01       | 13324      | City of Riverside | 3520 Central Ave.,<br>Riverside, Riverside County                                                 | SSO        | 600            | An estimated 600 gallons of sewage overflowed from a manhole due to an unspecified blockage. Approximately 200 gallons of the spill were contained, recovered, and returned to the operational sewer system. The rest of the spill discharged into a nearby storm drain. The blockage was cleared and the affected area was cleaned up by City of Riverside staff.              |
| 5/1/01        | 5/1/01        | 11969      | EMWD              | Between Lasselle St. and Iris Ave., close to Moreno Beach Dr.,<br>Moreno Valley, Riverside County | UTTW       | 118,000        | An estimated 118,000 gallons of undisinfected tertiary treated water (UTTW) was delivered as irrigation water from Moreno Valley Regional Water Reclamation Facility (MVRWRF) to recycled water users in the City of Moreno Valley due to chlorine injection equipment failure. EMWD's staff repaired the equipment and notified recycled water users.                          |
| 5/10/01       | 5/9/01        | 12026      | City of Rialto    | 501 East Santa Ana Ave. Rialto, San Bernardino County                                             | Sludge     | 5,400          | An estimated 5,400 gallons of sludge overflowed from a secondary digester due to a rapid rate of sludge flowing from the primary digester. All of the sludge remained on the treatment plant site. The cause of the sludge overflow was an equipment failure in the primary digester. City of Rialto staff picked up the sludge, cleaned up, and disinfected the affected area. |

## SANTA ANA REGIONAL WATER QUALITY CONTROL BOARD

### SEWAGE SPILL INCIDENTS (500 GALLONS AND ABOVE)

| Reported Date | Date of Spill | Notif. No. | Responsible Party               | Incident Location                                              | Spill Type | Volume Spilled | Description of Incident                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                            |
|---------------|---------------|------------|---------------------------------|----------------------------------------------------------------|------------|----------------|------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| 5/14/01       | 5/12/01       | 12141      | Private Party<br>Sheraton Hotel | 900 Disneyland Drive, Anaheim, Orange County                   | SSO        | 2,400          | An estimated 2,400 gallons of sewage overflowed from a manhole due to an 8" sewer line blocked with grease. 100 gallons of the spill were contained, recovered, and returned to the operational sewer system. The rest of the spill discharged into a local storm drain and flowed to Anaheim Barber Channel. As a result, OCHCA closed the harbor water area at Sunset Aquatic Park and Portofino Cove in Huntington Harbor to swimming and diving. City of Anaheim staff cleared the blockage and disinfected the affected area. |
| 5/15/01       | 5/15/01       | 12151      | City of Fullerton               | 2154 N. Derek Dr. & Milton Ave., Fullerton, Orange County      | SSO        | 2,360          | An estimated 2,360 gallons of sewage overflowed from a manhole due to an 8" sewer line blocked with tree roots. 200 gallons of the spill were contained, recovered, and returned to the operational sewer system. The rest of the spill discharged into a local storm drain and flowed to Fullerton Creek Channel. The Fullerton City staff cleared the blockage, cleaned up, and disinfected the affected area.                                                                                                                   |
| 5/16/01       | 5/14/01       | 12762      | City of Garden Grove            | Between Hazard and Brookhurst Ave, Garden Grove, Orange County | SSO        | 750            | An estimated 750 gallons of sewage overflowed from a manhole due to an unknown blockage. About 650 gallons of the spill were contained, recovered, and returned to the operational sewer system while the rest of the spill discharged into a local storm drain. The blockage was cleared, the affected area was cleaned up, and disinfected by Garden Grove City staff.                                                                                                                                                           |

## SANTA ANA REGIONAL WATER QUALITY CONTROL BOARD

### SEWAGE SPILL INCIDENTS (500 GALLONS AND ABOVE)

| Reported Date | Date of Spill | Notif. No. | Responsible Party              | Incident Location                                       | Spill Type | Volume Spilled | Description of Incident                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                       |
|---------------|---------------|------------|--------------------------------|---------------------------------------------------------|------------|----------------|-------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| 5/17/01       | 5/17/01       | 12243      | Private party Business Complex | 2200 South Mountain Ave. Ontario, San Bernardino County | SSO        | 1,000          | An estimated 1,000 gallons of sewage overflowed from a 4" private lateral (Business Complex) due to unknown debris. 900 gallons of the spill were contained, recovered, and returned to the operational sewer system. The rest of the spill was not recovered and it discharged into a local storm drain. The City of Ontario staff cleared the blockage, cleaned up, and disinfected the affected area.                                                                                                                                                                      |
| 5/17/01       | 5/17/01       | 13221      | City of Garden Grove           | 6517 Edgebrook Dr., Garden Grove, Orange County         | SSO        | 650            | An estimated 650 gallons of sewage overflowed from a manhole due to a grease blockage. About 550 gallons of the spill were contained, recovered, and returned to the operational sewer system. The blockage was cleared; the affected area was cleaned up, and disinfected by Garden Grove City staff.                                                                                                                                                                                                                                                                        |
| 5/18/01       | 5/18/01       | 13218      | City of Garden Grove           | Valley View St., Garden Grove, Orange County            | SSO        | 13,100         | An estimated 13,100 gallons of sewage overflowed from a 10" aluminum pipe which is temporarily replacing the force main. Two sections of the aluminum pipe had collapsed and ruptured. 10,400 gallons of the spill were contained, recovered, and returned to the operational sewer system. 2,700 gallons of the spill discharged into a local storm drain. Due to this spill, OCHCA closed part of Huntington Beach from Sunset Aquatic Marina to Portofino Cove. The City of Garden Grove staff repaired the temporary line, cleaned up, and disinfected the affected area. |

## SANTA ANA REGIONAL WATER QUALITY CONTROL BOARD

### SEWAGE SPILL INCIDENTS (500 GALLONS AND ABOVE)

| Reported Date | Date of Spill | Notif. No. | Responsible Party                     | Incident Location                                              | Spill Type | Volume Spilled | Description of Incident                                                                                                                                                                                                                                                                                                                                                                                                      |
|---------------|---------------|------------|---------------------------------------|----------------------------------------------------------------|------------|----------------|------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| 5/22/01       | 5/22/01       | 13325      | City of Grand Terrace                 | Between Barton and Mt. Vernon, Grand Terrace, Riverside County | SSO        | 1,800          | An estimated 1,800 gallons of sewage overflowed from a manhole due to a debris blockage. The spill went into the gutter, entered a local storm drain and pooled in a detention basin area. It was contained, recovered, and returned to the operational sewer system. The blockage was cleared, the affected area was cleaned up, and disinfected with chlorine bleach by Grand Terrace City staff.                          |
| 5/23/01       | 5/23/01       | 13326      | Private Party, Ralphs Shopping Center | 5351 University Ave., Irvine, Orange County                    | SSO        | ---            | An unknown amount of sewage overflowed from a private party's 4" lateral due to a debris/grease blockage. An estimated 1,000 gallons of the spill discharged into a local storm drain and was not recovered. The rest of the spill was contained, recovered, and returned to the operational sewer system. The blockage was cleared, the affected area was cleaned up, and disinfected by Irvine Ranch Water District staff. |
| 5/26/01       | 5/26/01       | 13217      | Orange County Sanitation District     | Between Calle Baja and Grande, Orange, Orange County           | SSO        | 500            | An estimated 500 gallons of sewage overflowed from a manhole due to a root blockage. All of the spill was contained in the storm drain, recovered, and returned to the operational sewer system. The blockage was cleared, the affected area was cleaned up, and disinfected by OCSD staff.                                                                                                                                  |

## SANTA ANA REGIONAL WATER QUALITY CONTROL BOARD

### SEWAGE SPILL INCIDENTS (500 GALLONS AND ABOVE)

| Reported Date | Date of Spill | Notif. No. | Responsible Party                      | Incident Location                                        | Spill Type | Volume Spilled | Description of Incident                                                                                                                                                                                                                                                                                                                                                                                     |
|---------------|---------------|------------|----------------------------------------|----------------------------------------------------------|------------|----------------|-------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| 5/29/01       | 5/29/01       | 13197      | Private Party<br>Balboa Bay Club       | 1221 West Coast Highway. Newport Beach, Orange County    | SSO        | ---            | An Unknown amount of sewage leaked from a 2" bulkhead of the sewer line. This sewer line transfers sewage from a vessel pump-out station to Balboa Bay Club's (BBC) sewer system. OCHCA closed part of Newport Bay area from "F" through "H" Docks at the BBC, and the Orange Coast College Crew Docks to swimming and diving. BBC's maintenance crew repaired the bulkhead and shut down the pump station. |
| 6/1/01        | 6/1/01        | 13219      | Private Party,<br>Ocean Air Apartments | 7811 Talbert Ave.,<br>Huntington Beach,<br>Orange County | SSO        | 1,000          | An estimated 1,000 gallons of sewage was released from a private party's lateral due to a sewer line leakage. None of the spill was recovered. It discharged into a local storm drain which entered Huntington Central Park Lake. Swimming is not allowed at the lake. Repairs were made to the sewer line and the immediate area was cleaned up by City of Huntington Beach staff.                         |
| 6/2/01        | 6/2/01        | 13267      | Garden Grove                           | 1277 West Fern,<br>Garden Grove,<br>Orange County        | SSO        | 1,000          | An estimated 1,000 gallons of sewage overflowed from a manhole due to a grease blockage. About 600 gallons of the spill were contained, recovered, and returned to operational sewer system while the rest of the spill discharged into a nearby storm drain. The blockage was cleared, the area was cleaned up, and disinfected by Garden Grove City staff.                                                |



## SANTA ANA REGIONAL WATER QUALITY CONTROL BOARD

### SEWAGE SPILL INCIDENTS (500 GALLONS AND ABOVE)

| Reported Date | Date of Spill | Notif. No. | Responsible Party                    | Incident Location                                            | Spill Type | Volume Spilled | Description of Incident                                                                                                                                                                                                                                                                                                                                                                                                                                                                  |
|---------------|---------------|------------|--------------------------------------|--------------------------------------------------------------|------------|----------------|------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| 6/3/01        | 6/3/01        | 13270      | Private Party                        | 1650 S. Campus Ave., Ontario, San Bernardino County          | SSO        | 6,000          | An estimated 6,000 gallons of sewage overflowed from a private party's manhole due to an oil/grease blockage. Most of the spill was contained, recovered, and returned to the operational sewer system. The rest of the spill percolated into the ground. The blockage was removed, the area was cleaned up, and disinfected by City of Ontario staff.                                                                                                                                   |
| 6/4/01        | 6/4/01        | 13177      | Private Party                        | 8990 Cottage Street, Rancho Cucamonga, San Bernardino County | SSO        | 12,000         | An estimated 12,000 gallons of sewage overflowed from several toilets and an 8" sewer main (all on private property) due to a blockage of wood chips and debris. The majority of the spill discharged into a local storm drain. A small amount of the spill was contained, recovered and returned to the operational sewer system. RCWD's staff cleared the blockage, cleaned, and disinfected the affected area.                                                                        |
| 6/9/01        | 6/8/01        | 13179      | Private Party<br>Tipper & Associates | 8602 Westminster, Huntington Beach, Orange County            | SSO        | 2,000          | An estimated 2,000 gallons of sewage overflowed from a 4" private lateral due to a grease blockage. 1,500 gallons of the spill flowed through the Newland to Westminster Channel and into Huntington Harbor. OCHCA closed the Harbor from Sunset Aquatic Marina to Portofino Cove. 500 gallons of the spill were contained, recovered, and returned to the operational sewer system. City of Huntington Beach staff cleared the blockage, cleaned up, and disinfected the affected area. |

## SANTA ANA REGIONAL WATER QUALITY CONTROL BOARD

### SEWAGE SPILL INCIDENTS (500 GALLONS AND ABOVE)

| Reported Date | Date of Spill | Notif. No. | Responsible Party         | Incident Location                                        | Spill Type | Volume Spilled | Description of Incident                                                                                                                                                                                                                                                                                                                                                                   |
|---------------|---------------|------------|---------------------------|----------------------------------------------------------|------------|----------------|-------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| 6/15/01       | 6/11/01       | 13220      | Jurupa Community Services | Between Whitney, Mt. Rainer, Riverside, Riverside County | SSO        | 700            | An estimated 700 gallons of sewage overflowed from a manhole due to a grease blockage. Approximately 350 gallons of the spill were contained, recovered, and returned to the operational sewer system. The blockage was cleared, the affected area was cleaned up, and disinfected with bleach by Jurupa Community Services staff.                                                        |
| 6/19/01       | 6/16/01       | 13349      | City of Newport Beach     | 26 Vienna Str., Newport Beach, Orange County             | SSO        | 3,500          | An estimated 3,500 gallons of sewage was released from a relief valve for four days due to a high level alarm failure at the pump station. The spill was not recovered and discharged into a nearby private storm drain. The relief valve was repaired, the affected area was cleaned and disinfected by Newport Beach staff.                                                             |
| 6/22/01       | 6/22/01       | 13406      | Private party             | 1200 South Standard, Santa Ana, Orange County            | SSO        | 1,200          | An estimated 1,200 gallons of sewage overflowed from a 4" lateral of an apartment complex due to an oil/grease blockage. The City of Santa Ana staff assisted the contractor in relieving the blockage, containing, recovering, and returning all the spill to the operational sewer system. The blockage was cleared, the affected area cleaned and disinfected by Santa Ana City staff. |